

Report sponsor	Certificate issue date	Certificate no.	
Parchem Construction Supplies Pty Ltd 7 Lucca Road Wyong, NSW 2259 Australia	21 January 2019	SFC FRT190002	
Introduction			
The element of the construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.			
Referenced report	Test standard	Test date	Referenced report issue date
FRT190002.1	AS 1530.4:2005	30 July 2014	10 January 2019

Description of the test specimen

The test assembly comprised of six control joints protected with Parchem Fosroc Flamex XT sealant and 50mm Open Cell PE foam backing rod in a 1760mm x 1900mm wall. One half of the wall comprised of 75mm Hebel panel stripes and the other was 120mm concrete slab stripes. The concrete half was penetrated by 3-off vertical joints (A, B & C) and the Hebel half was penetrated by 2-off vertical joint (E & F). An additional joint (D) was located between the Hebel and concrete section.

Penetration system	Sealant Width	Depth	Protected side	FRL
A	40mm	20mm	Exposed	-/180/30
B	40mm	20mm	Exposed and unexposed	-/240/120
C	20mm	10mm	Exposed	-/240/30
D	40mm	20mm	Exposed and unexposed	-/120/60
E	40mm	20mm	Exposed	-/180/30
F	20mm	10mm	Exposed	-/120/30

Refer to the referenced report for a complete description of the test specimen.

Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia Pty Ltd are subject to, and conducted in accordance with, the Standard Terms and Conditions of Warringtonfire Australia Pty Ltd, which are available at <https://www.element.com/terms/terms-and-conditions> or upon request.
- Exova Warringtonfire rebranded to Warringtonfire on 1 December 2018. Apart from the change to our brand name, no other changes have occurred. The introduction of our new brand name does not affect the validity of existing documents previously issued by us.

Testing authority	Warringtonfire Australia Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
Phone	T: +61 (0)3 9767 1000	
ABN	81 050 241 524	
Email	info.fire.melbourne@warringtonfire.com	
Authorisation	Prepared by:	Reviewed by:
		
	Patrick Chan	Mandeep Kamal