


**Boral Construction Materials
Materials Technical Services**

 Unit 4, 3-5 Gibbon Road
 Baulkham Hills NSW 2153 Australia
 PO Box 400, Winston Hills NSW 2153

T: +61 (02) 9624 9900

F: +61 (02) 9624 9999

www.boral.com.au

TEST REPORT – CURING COMPOUND

CLIENT: EVENRANGE PTY LTD

Address: 12 Frankston Garden Drive, Carrum Downs, VIC 3201

REQUEST NO.: 89050**FILE NO.: 258/20**

LAB. SAMPLE NO.: 234010

JOB DESCRIPTION: CURING COMPOUND EVALUATION

TEST METHOD: AS 3799 - 1998

DISTRIBUTOR: Parchem

SAMPLE IDENTIFICATION: Concure X90

SAMPLE DESCRIPTION: Water-based Hydrocarbon resin curing compound

CLASSIFICATION: Class B, Type 1

SAMPLE SOURCE: VIC

DATE SAMPLED: 03/03/2020

DATE RECEIVED: March 2020

DATE TESTED: 05-22/05/2020

METHOD OF APPLICATION: by spraying at standard application rate of 5m²/L**TEST RESULTS:**

Standard property, Test (Method)	Specification	Result
Water retention efficiency AS 3799.3.1.2 (Appendix B)	Min. 90 %	92%
Non - volatile content* AS 3799.3.1.8 (Method AS 1580.301.1)	N / A	41.78%
Density* AS 3799.3.1.9 (Method AS/NZS 1580.202.1)	N / A	0.972
Viscosity* AS 3799.3.1.5 (Method AS/NZS 1580.214.5)	Min. 0.05 Pa's	0.23 Pa's
Drying Time* AS 3799.3.1.4 (Appendix C)	Max. 4 hrs	4 hrs
Infrared absorption spectrum* AS 3799.3.2 (Boral In-house Method)	N / A	attached
Stability of emulsion* RMS T862	Max 4%	1.8%
Residue 150µm* AS 3799.3.1.6 (Method AS/NZS 2341.20)	Max. 0.2%	<0.1%

Notes:

- Sample supplied by the client and tested as received.
- * Test method not covered by the current scope of accreditation for our laboratory.

Kane Latham, Mat File, File


 Approved Signatory: Julius C. Alvaro Julius Alvaro
 Date: 25/05/2020 Serial No. CEM89050.JA.2

 Accredited for compliance with ISO/IEC 17025 - Testing
 This report shall not be reproduced except in full without the approval of the Boral MTS Laboratory
 Test results in this Test Report relate only to the samples tested


NATA Accredited Laboratory

Number: 547

BORAL MATERIALS TECHNICAL SERVICES LABORATORY
REQUEST No: 89050

CLIENT: EVENRANGE PTY LTD

FILE No 158/20



LSN 234010 Evencure XDS - NX - Gen, 00228B Type 1, Class B Product Name : Parchem Distributor : Concure X90

NO 20205/20