

VOC Content Test Certificate

Thursday March 13th, 2008

Manufacturer: Parchem Construction Products

7 Lucca Road

Wyong NSW 2259

Sample Description: Nitomortar 903 epoxy coating

Date Tested: March 2008

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Nitomortar 903
Interior Sealer 65 grams per Litre	12 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0803-08